



**DEPARTMENT OF THE AIR FORCE**  
28TH MEDICAL GROUP (ACC)  
ELLSWORTH AIR FORCE BASE, SOUTH DAKOTA

27 February 2015

MEMORANDUM FOR RECORD

FROM: 28 MDOS/SGOJ

SUBJECT: February 2015 Compliance Water Monitoring Results

1. During the month of February 2015, Bioenvironmental Engineering (BE) collected 9 samples from state approved sites. Sampling is performed each month based on monitoring frequency requirements outlined in AFI 48-144, *Drinking Water Surveillance Program*, Para 4.1., and South Dakota Department of Environmental and Natural Resources (SD DENR) guidance. Below is a summary of samples collected in the month of February.

Site	Chlorine	pH	Bacteriological	Fecal
Bldg. 7925, BW HQ	1.0	7.6	Absent	Absent
Bldg. 7251, Control Room	1.0	7.7	Absent	Absent
Bldg. 477, Roosevelt Dr.	0.9	7.7	Absent	Absent
Bldg. 7430, ALS	1.1	7.7	Absent	Absent
Bldg. 600, Vandenberg Elementary	1.0	7.5	Absent	Absent
Bldg. 102, LRS	0.5	7.5	Absent	Absent
Bldg. 8003, CDC	1.0	7.7	Absent	Absent
Bldg. 132, Maple Dr.	1.1	7.6	Absent	Absent
Bldg. 7712, Youth Center	0.3	7.7	Absent	Absent

2. Drinking water standards set by the Environmental Protection Agency (EPA) and SD DENR, prescribe acceptable levels of chlorine and pH within a water system. Chlorine residual is maintained between 0.1-2.0 mg/L and pH at levels between 6.5 and 8.5. All samples are in compliance with EPA and state standards. Please contact BE at 385-3172 with any questions.

JAMES D. REILLY, Capt, USAF, BSC  
Bioenvironmental Engineering Flight Commander